



## Certificate of constancy of performance

0099/CPR/A43/0593

In compliance with Construction Products Regulation 305/2011/EU of the European Parliament and of the Council, of 9 March 2011, the notified body AENOR (n. 0099) has issued this certificate to

**SAINT-GOBAIN ISOVER IBERICA, S.L.**

registered office CL PRINCIPE DE VERGARA, 132 28002 MADRID (España)

Construction Product **Mineral Wool for building equipment and industrial installations**

Harmonised Standard EN 14303:2009+A1:2013

Trade Mark CLIMAVER A1 APTA

See annex for more information.

Production site AVENIDA DEL VIDRIO, S/N 19200 AZUQUECA DE HENARES (Guadalajara - España)

Certification scheme This certificate attests that all provisions under system 1 concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the aforementioned harmonised standard are applied and that the product fulfils all the prescribed requirements set out above.

This certificate will remain valid until its validity date, provided that the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

First issued on 2015-02-16

Last issued on 2025-11-28

Validity 2026-11-28

Rafael GARCÍA MEIRO  
CEO



**AENOR CONFÍA S.A.U.**  
Génova, 6. 28004 Madrid. España  
Tel. 91 432 60 00.- [www.aenor.com](http://www.aenor.com)



## Certificate of constancy of performance

0099/CPR/A43/0593

### Annex to Certificate

Trade Mark CLIMAVER A1 APTA

| Range of thickness | Face A              | Reaction to fire as placed on the market for face A | Face B           | Reaction to fire as placed on the market for face B | Designation code   | Mean Temperature(°C) / Thermal Conductivity (W/mK) |
|--------------------|---------------------|-----------------------------------------------------|------------------|-----------------------------------------------------|--------------------|----------------------------------------------------|
| 40 - 50            | Reinforced aluminum | A1                                                  | Black fiberglass | A1                                                  | MW-EN 14303-T5-MV1 | 10/0,032<br>20/0,033<br>40/0,036<br>60/0,039       |

First issued on 2015-02-16  
Last issued on 2025-11-28  
Validity 2026-11-28



**AENOR CONFÍA S.A.U.**  
Génova, 6. 28004 Madrid. España  
Tel. 91 432 60 00.- [www.aenor.com](http://www.aenor.com)