



Certificate of constancy of performance

0099/CPR/A43/0561

In compliance with Construction Products Regulation 305/2011/EU of the European Parliament and of the Council, of 9 March 2011, the notified body AENOR (n. 0099) has issued this certificate to

SAINT GOBAIN ISOVER IBERICA, S.L.

registered office CL PRINCIPE DE VERGARA, 132 28002 MADRID (España)

Construction Product **Mineral Wool for building equipment and industrial installations**

Harmonised Standard EN 14303:2009+A1:2013

Trade Mark CLIMLINER Slab G1

See annex for more information.

Production site AV DEL VIDRIO, S/N 19200 AZUQUECA DE HENARES (Guadalajara - España)

Certification scheme This certificate attests that all provisions under system 1 concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the aforementioned harmonised standard are applied and that the product fulfils all the prescribed requirements set out above.

This certificate will remain valid until its validity date, provided that the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

First issued on 2014-11-28

Last issued on 2024-11-28

Validity 2025-11-28

Rafael GARCÍA MEIRO
CEO



AENOR CONFÍA S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com



Certificate of constancy of performance

0099/CPR/A43/0561

Annex to Certificate

Trade Mark CLIMLINER Slab G1

| Range of thickness | Face A | Reaction to fire as placed on the market for face A | Face B | Reaction to fire as placed on the market for face B | Designation code | Mean Temperature(°C) / Thermal Conductivity (W/mK) |
|--------------------|------------------|---|-----------------------|---|------------------|--|
| 15 - 100 | Black fiberglass | A2-s1, d0 | Reinforced glass veil | A2-s1, d0 | MW-EN 14303-T3 | 10/0,032 20/0,034 40/0,037 60/0,040 |

First issued on 2014-11-28
Last issued on 2024-11-28
Validity 2025-11-28



AENOR CONFÍA S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com