



Certificate of constancy of performance

0099/CPR/A43/0508

In compliance with Construction Products Regulation 305/2011/EU of the European Parliament and of the Council, of 9 March 2011, the notified body AENOR (n. 0099) has issued this certificate to

SAINT GOBAIN ISOVER IBERICA, S.L.

registered office CL PRINCIPE DE VERGARA, 132 28002 MADRID (España)

Construction Product **Mineral Wool for building equipment and industrial installations**

Harmonised Standard EN 14303:2009+A1:2013

Trade Mark CLIMAVER A2 APTA

See annex for more information.

Production site AV DEL VIDRIO, S/N 19200 AZUQUECA DE HENARES (Guadalajara - España)

Certification scheme This certificate attests that all provisions under system 1 concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the aforementioned harmonised standard are applied and that the product fulfils all the prescribed requirements set out above.

This certificate will remain valid until its validity date, provided that the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

First issued on 2014-11-28

Last issued on 2022-11-28

Validity date 2023-11-28

Rafael GARCÍA MEIRO
Chief Executive Officer





Certificate of constancy of performance

0099/CPR/A43/0508

Annex to Certificate

Trade Mark CLIMAVER A2 APTA

Range of thickness	Face A	Reaction to fire as placed on the market for face A	Face B	Reaction to fire as placed on the market for face B	Designation code	Mean Temperature(°C) / Thermal Conductivity (W/mK)
40 - 50	Kraft-aluminum foil reinforced of fiberglass mesh	A2-s1, d0	Black fiberglass reinforced	A2-s1, d0	MW-EN 14303-T5-MV1	10/0,032 20/0,033 40/0,036 60/0,039

First issued on 2014-11-28
Last issued on 2022-11-28
Validity date 2023-11-28

